CENBOSEC, Delhi – 92 E-Mail: cbsedli@nda.vsnl.net.in



Phone: 22509256-59 Fax: 22515826 website: <u>www.cbse.nic.in</u>

CENTRAL BOARD OF SECONDARY EDUCATION

(An Autonomous Organisation under the Union Ministry of Human Resource Development Govt. of India)
"SHIKSHA KENDRA", 2, COMMUNITY CENTRE, PREET VIHAR, DELHI –
110092

F2017	/LTP/NICPD/Grg./2013/	31.12.2013
•••••	•••••••••••••••••••••••••••••••••••••••	
•••••	•••••••	
•••••	••••••	
Sub:	Limited Tenders for SITC of LT Panel & AMF Panel at NICPD, Gurg	<u>aon</u>
Sir,		

The CBSE intends to select a suitable agency for SITC of LT Panel & AMF Panel at NICPD, Gurgaon. The agencies of high repute with minimum 5 years experience and having executed two (2) similar works each costing Rs. 1.50 lakh or more in reputed organizations need apply. An EMD of Rs. 5,000/- payable through DD/BD in f/o the Secretary, CBSE must be attached. The work is urgent and time bound. The rates are to be quoted on the schedule annexed herewith. Last date to submit the quotations is 07.01.2014 upto 2.00 p.m.

Incomplete & conditional tenders shall be summarily rejected. The Secretary, CBSE reserves the right to reject any or all the tenders without assigning any reason thereof.

(S.K.Sharma) Consultant(Tech.)

Schedule of work

Name of work : SITC of LT Panel & AMF Panel at NICPD, Gurgaon PART – A

S.No.	Description	Make	Qty.	Rate	Amount
1.	400 ATPN MCCB (36KA)	L&T	1 No.		
	WITH ROTARY				
	HANDEL+SPANDER				
	TERMINAL				
2.	200 ATPN MCCB (36KA)	L&T	1 No.		
	WITH ROTARY				
	HANDEL+SPANDER				
	TERMINAL				
3.	125 ATPN MCCB (36KA)	L&T	1 No.		
	WITH ROTARY				
	HANDEL+SPANDER				
	TERMINAL				
4.	100 ATPN MCCB (36KA)	L&T	1 No.		
	WITH ROTARY				
	HANDEL+SPANDER				
	TERMINAL				
5.	63 ATPN MCB (FOR	L&T	3 Nos.		
	LIGHTING)				
6.	A+V (DIGITAL)	Conzerv	2 Nos.		
7.	ROTARY SWITCH	Salzer	2 Nos.		
	(ASS+VSS)				
8.	INDICATION LAMP	Vashno	3 Nos.		
	(LED)				
9.	CT 300/5 AE	AE	3 Nos.		
10.	S/P MCB 6A	L&T	3 Nos.		
11.	FABRICATION 1.6MM		JOB		
	CRC SHEET POWDER		work		
	COATED (SIEMENCE				
	GRAY)				
12.	BUS BAR (30X12)	Hindalco	1 set		

Panel size shall be 1575 x 1200 x 300 mm.

Name of work : SITC of LT Panel & AMF Panel at NICPD, Gurgaon

PART B

S.No.	Description	Make	Qty.	Rate	Amount
1.	Contractors MCX33 4	L&T	2 Nos.		
	Pole AC Duty				
2.	MCCB 125A TPN With	L&T	2 Nos.		
	Rotary Handel				
3.	Multy Function meter	Sanieder	1 No.		
	A+V+F+KW+PF+KVA				
4.	ADC	AE	1 No.		
5.	Annanciation window	Taknika	1 No.		
	LLOP +HWT+SET Fail to				
	start				
6.	UVR + AVR+ On Delay	Teknika/FTC	6 Nos.		
	Timer ESR (12v)				
7.	S/P MCB	L&T	10 Nos.		
8.	BATTERY CHARGER	MAHAMAI	1 No.		
9.	AUTO MANUL SWITCH	L&T	1 No.		
10.	INDICATION	FTC	8 Nos.		
	LAMP+PUSH BUTTON				
11.	CRANKING RELAY	SALZER	1 no.		
	(12V)				
12.	СТ	AE	3 No.		
13.	WIRE	HPL			
14.	FABRICATION 1.6MM				
	CRC SHEET				
15.	BUSBAR (25X10)	Hindalco			

Panel Size = 1475 mm x 700mm x 350mm

(Signature of the tenderer)
With complete address and seal
Tel No
Mobile No
Place
Date

Terms and conditions

- 1. All the materials must comply the I:S standards/approved brands.
- 2. The work is to be completed within 07 days from the date of work order.
- 3. In case of delay, a penalty @ 1% per week shall be levied.
- 4. In case of slow progress/stoppage of work without valid reasons, the Board shall have the power to rescind the work get the same executed at the risk& cost of the defaulting agency.
- 5. In no case unspecified material is to be brought at site.
- 6. The work has to be executed as per the CPWD specifications as well as best engg. Practices.
- 7. In case of poor workmanship, the work shall be got redone by the agency without any extra charge.
- 8. The elect. Copper cables shall be of Kalinga/Havell's/Plaza/Anchor/Finolex.
- 9. The MCB's shall be of Havells/Anchor/Standard/Hager L&T/EE.
- 10. The agency must be CPRI approved and the product must comply the norms.

(Signature of the tenderer)
With complete address and seal
Tel No
Mobile No
Date