

Central Board of Secondary Education

“SHIKSHA KENDRA”, 2 COMMUNITY CENTRE, PREET VIHAR, DELHI-110092

TENDER NOTICE

Sealed tenders are invited from reputed agencies (Approved by CPRI) registered with Govt/PSU/Autonomous bodies for the work of SITC of LT Panels in Basement CBSE Preet Vihar Bldg. Agencies having executed a minimum of 3 works of value 3.0 lacs each or two works of value Rs. 5.0 lacs or more may apply. Cost of tender documents Rs. 500/- & EMD amounting to Rs. 35,000/- payable through DD/BD in f/o the Secretary, CBSE & experience documents must be annexed. Sealed envelopes of superscribed SITC of LT Panels in Basement CBSE Preet Vihar Bldg. Tender documents can be downloaded from Board's Website: www.cbse.nic.in. Tender complete in all respect must be submitted latest by 24.01.2014 upto 2.30 p.m. and dropped in the tender-box placed at Reception Counter, HQ, Bldg. Preet Vihar, Delhi-110092. Tender would be opened at 3:00 p.m. or same day. Secretary CBSE has the right to reject any or all tender without assigning any reason.

Joint Secretary (A& L)

Schedule of work

Name of Work: SITC of LT Panels in Basement CBSE Preet Vihar Bldg.

S.NO	Description of Item	Qty	Unit	Rate	Amount
1.	Supply Installation, testing & commissioning of Elect. Panel of Size 2325mm X 2800mm X500 made of 1.6mm CRC sheet LT Panel-II for 62.5 KVA with the following : a) 400A TPN MCCB (50KA) with Rotary handles of L&T make - 1Nos b) 200A TPN MCCB (36KA) with Rotary handles of L&T make - 12 Nos c) 300A TPN MCCB (36KA) with Rotary handles L&T make -2 Nos d) MF Meter of Conzerv make -1 Nos e) Indication Lamp of Vaisno make - 3 Nos f) S/P MCB 6A/16A of L&T make - 3 Nos g) Indication Lamp of Nos Vaisno make - 3 Nos h) Busbar (Aluminium) 40X10 of make for Hindalco make - 1 set	1	Each		
2	Supply Installation, testing & commissioning of Elect. Panel of Size 2325mm X 2800mm X500 made of 1.6mm CRC sheet LT Panel -I for 320 KVA with the following : a) 1600A TPN MCCB (50KA) with Rotary handles of L&T make - 2 Nos b) 200A TPN MCCB (36KA) with Rotary handles of L&T make - 12 Nos c) 300A TPN MCCB (36KA) with Rotary handles of L&T make- 2 Nos d) MF Meter of Conzerv make - 1 Nos e) Indication Lamp of Vaisno make - 3 Nos f) S/P MCB 6A/16A of make L&T - 3 Nos g) Indication Lamp of Vaisno make - 3 Nos h) Busbar (Aluminium) 40X10 of Hindalco make - 1 set.	1	Each		

S.NO	Description of Item	Qty	Unit	Rate	Amount
3	<p>Supply Installation, testing & commissioning of Elect. Panel of Size 2325mm X 2800mm X500 made of 1.6mm CRC sheet 300 KVA R APFC Panel with the following :</p> <p>a) 630 TP MCCB of L&T make - 1Nos b) MCCB 100 ATP of L&T make – 3 Nos c) 95A Contactor of L&T make -3 Nos d) VAF meter of Cadel make -1 Nos e) APFC relay (16 stage) of Syntron make- 1 Nos f) Rotary Switch of SALZER make -15 Nos g) Indication Lamp of Vaisno make - 15 Nos h) S/P MCB 6A/16A of - 18 Nos i) 50A + 32A +25A contactor of L&T make 15 Nos j) 63A +32A +20A MCB TP of L&T make- 12 Nos k) 50X3 , 25X3 ,15X3 ,10X1 ,5X3 ,3X1 ,2X1 ,heavy duty Capacitors of Siemns/L&T make - 20 Nos l) Busbar (Aluminium) of Hindalco make -1 set</p>	1	Each		
4	<p>Supply Installation, testing &commissioning of Elect. Panel of Size 2325mm X 2800mm X500 made of 1.6mm CRC sheet with the following :</p> <p>a) Termination Thimble of Dowell make b) Jonson Tape make c) Cable Gland of APC make</p>	95 85 90	Each Each Each		
5	Removal of Existing LT Panel and Disposal (Agency to quote buy back rate for old Panel.)				

Terms and Conditions

1. All the material must comply the I: S standards/approved brands.
2. The work is to be complete within 20 days from the date of work order.
3. In case of delay, a penalty @1% per week shall be levied.
4. In case of slow progress/stoppage of work without valid reason, the Board shall have the power to rescind the work get the same executed at the risk & cost of the defaulting agency.
5. In no case unspecified material is to be brought at site.
6. The work has to be executed as per the CPWD specifications as well as best engg. Practices.
7. In case of poor workmanship, the work shall be got redone by the agency without any extra charge.
8. The elect, Copper shall be of Kalinga/Havell's/Plaza/Anchor/Finolex.
9. The MCB's shall be of Havells/Anchor/Standard/Hagar L&T/EE.
10. The agency must be CPRI approved and the product must comply the norms.

(Signature of the tenderer)
With complete address and seal

Tel No.....

Mobile No.....

Date.....