

Gram : CENBOSEC, Delhi – 92
E-Mail: cbsecli@nda.vsnl.net.in



Phone: 22509256-59
Fax: 22515826
website: www.cbse.nic.in

CENTRAL BOARD OF SECONDARY EDUCATION

(An Autonomous Organisation under the Union Ministry of Human Resource Development Govt. of India)

“SHIKSHA KENDRA”, 2, COMMUNITY CENTRE, PREET VIHAR, DELHI – 110092

F-53-C/DM/SQ/2012

Date:22.12.2012

.....
.....
.....
.....

Sub: - Limited Tender for Earthing work in CBSE Staff Qtrs. at Brij Vihar (GZB)

Sir,

The CBSE intends to provide Earthing System in its staff qtrs., Brij Vihar (GZB). Agencies having at least 3 years experience in the Electrical field may apply on the prescribed format annexed herewith. An EMD of Rs. 3000/- payable through DD/BD in f/o the Secretary, CBSE, Delhi-110092 is to be enclosed. The last date for submission of the tender is 07.01.2013 upto 2.30 p.m. and the same shall be opened at 3.00 p.m. The tenders complete in all respect be dropped in the Tender-Box placed at Reception Counter, HQ Bldg. Preet Vihar, Delhi-110092.

Incomplete and conditional tenders shall be summarily rejected. The CBSE reserves the right to reject any or all the tenders without assigning any reason thereof.

Yours faithfully

(S.K. SHARMA)
Superintending Engineer

SCHEDULE OF WORK

S.NO	DESCRIPTION OF ITEM	QTY.	UNIT	RATE	AMOUNT
1.(a)	G.I. earth plate electrode: Earthing with G.I. earth plate 600mm x 600mm x 6mm thick including accessories, and providing masonry enclosures with cover plate having locking arrangement and watering pipe etc. (but without charcoal or coke and slat) as required.	12	Each		
(b)	Slat/coke for plate earth electrode: Extra for using salt and charcoal for G.I. or copper plate earth electrode as required.	12	Each		
2.	P&F MS Box, Powder coated with 80 microns or more (Earth Termination Box) of size 200x300 mm with cover & Earth termination aluminium strip size 200x50x6 mm with termination holes suitably clamped for further distribution of earth connections (upto the ht. of 3 mtrs)	12	Each		
3.	Supplying & lying 6 SWG G.I. wire in recessed/surface PVC conduit of size 19 mm i/c end termination through soldered thimbles at both ends.	360	Mtrs.		
4.(a)	Supplying & lying 25 x 6 mm G.I. earth strip from earth electrode in 40 mm dia G.I. pipe, as required.	100	Mtr.		
(b)	P&F earth electrode 25x 6 mm G.I. strip through 32 mm recessed PVC pipe/40 mm casingcapping (upto ht. of 3 mtr. from Earth electrode)	48	Mtr.		

GROSS TOTAL=

Accepted by me
Signature
Prop. /Manager
Tel. No./Mob. No.

Terms & Conditions

1. The work shall be executed as per the CPWD specifications and best engineering norms.
2. The work is time bound, hence time is the essence of the contract.
3. The work is to be completed within 45 days from 7th day of award of work.
4. All the materials shall be got approved from the Engineer-in-charge before installation.
5. No T & P shall be provided by the Board.
6. Scaffolding shall be arranged by the Contractor.
7. The work shall be executed under the strict supervision of the Board's J.E/ S.E.
8. The measurements shall be recorded jointly.
9. An affidavit certifying five years guarantee failure of earth electrode shall be given on Rs.10/- non-judicial stamp paper duly attested by the Notary Public.
10. Potable water shall only be used, in no case ground water shall be used.
11. In case of delay, a penalty @ 1% per week shall be levied subject to a max of 5%.
12. In case of poor workmanship or inordinate delay, the Board shall have the right to rescind the contract and get the work executed through any other agency at the risk & cost of the defaulting contractor.
13. In case the work is kept suspended without any valid reason, the Board shall be free to get the remaining work executed through any other agency.
14. The contractor shall be required to provide adequate safety for its workers and the Board shall not be accountable to any kind of injury/ accident at site.
15. 10% amount shall be retained as security for a period of 6 months as defect liability. In case no defect is observed the same shall be released.
16. The masonry repairs shall be done nicely without undulation.

Accepted by me

Signature
Prop. /Manager
Tel. No.
Mob. No.